

#### 13.04.070 Three-ton capacity system - Limitation of use of water.

---

##### **13.04.070 – Three-ton capacity system - Limitation of use of water.**

Any air-conditioning system or additions thereto, resulting in a total capacity in excess of three tons installed on or after November 1, 1958, shall be equipped with a water regulating device and shall be limited to the use of water from the city mains and not to exceed 0.2 gallons per minute per ton of capacity, and on or after November 1, 1958, no permit shall be issued by the building official for any such above-described system, or addition thereto, unless said system is designed to limit the use of water from the city mains to 0.2 gallons per minute per ton of capacity.

(Prior code : § 15.403(E))